



# **60 Years of Development in Kraft Recovery Boiler Technology**

**Featuring FRBC Highlights**

**Keijo Salmenoja**

Partially retired from Black Liquor



# Contents

- Introduction
- Early development (bc FRBC)
- Foundation of FRBC (1964)
- Recent development (ad FRBC)
- FRBC highlights
- Summary




# Contents

- Introduction
- Early development (bc FRBC)
- Foundation of FRBC (1964)
- Recent development (ad FRBC)
- FRBC highlights
- Summary



# Introduction





# Contents

- Introduction
- Early development (bc FRBC)
- Foundation of FRBC (1964)
- Recent development (ad FRBC)
- FRBC highlights
- Summary



# Early Development (bc FRBC)

- Kraft pulping evolved from soda pulping, zero sulfidity kraft in Germany in the 1880s
- Typically, batch digesters were used 1920s
  - Capacity of 50-70 m<sup>3</sup>
- Black liquor recovery with refractory-lined roasting smelters
  - Heat recovery in an external heat recovery steam generator bank connected by ductwork




# Early Development (bc FRBC)

- The launch of the G. H. Tomlinson RB in early 1930s was a milestone in the kraft process
  - Heat recovery steam generator was mounted on top of the smelter reactor to avoid the ducting requirements
  - This minimized the building footprint, making the recovery boiler a dominating feature of the mill skyline




# Introduction

1934



2024









# Introduction

1934



2024





# Contents

- Introduction
- Early development (bc FRBC)
- **Foundation of FRBC (1964)**
- Recent development (ad FRBC)
- FRBC highlights
- Summary



# Foundation of FRBC

- Boiler pressures  $> 64$  bar lead to several failures in RB waterwall tubes in Finland
  - New phenomenon
  - Rapid furnace side corrosion of carbon steel wall tubes
- Average shutdown time ca. 46 days
- Cost to change the tubes ca. 500 000 FIM (~1 M€) per boiler



# Foundation of FRBC

- A national research project, involving all boiler suppliers and pulp producers was initiated in 1964 in Finland to find the reason for rapid wall tube corrosion
- First cooperation meeting was held at Kaukas mill on *November 11, 1964*
  - Initiate a study to solve wall tube corrosion and to create measures to mitigate the corrosion



# Foundation of FRBC

- A jointly sponsored 3-year *Recovery Boiler Corrosion Study* was started in 1965
- Formal cooperation between Finnish Recovery Boiler users and manufacturers was started
- Another study to develop a *Recovery Boiler Control Model* was launched as a separate project in 1970



# Foundation of FRBC

- Six different committees were nominated:
  - *Statistical, Furnace, Durability, Water Circulation, and Corrosion Outside Furnace*
- Furnace conditions were studied with gas composition, deposit, and temperature analyses
- A computer model was developed to process the measurement data



# Foundation of FRBC

- Final report was published in 1968:
  - Corrosion due to sulfidation by  $\text{H}_2\text{S}$  and  $\text{COS}$
  - Main contributor to corrosion rate was boiler pressure (wall tube metal temperature)
  - Highest corrosion rates in reducing areas, less corrosion in upper parts of the furnace
  - Recommendation how to protect furnace wall tubes against sulfidation corrosion



# Foundation of FRBC

**R** = reduction zone, **P** = combustion zone, **J** = OFA zone, **Y** = upper zone

Recommendation for new tubes*	R	P	J	Y
<b>Carbon steel tubing:</b>				
2 mm corrosion allowance	2	3	3	4
Al flame spray coating	0	0	2	2
Cr-Al flame spray coating	0	1	2	3
Cr-Fe flame spray coating	1	1	2	3
Cr-Fe weld overlay	4	4	4	NN
Cr steel tubes, membrane wall	4	4	4	NN
<b>Composite tubes</b>	4	4	4	NN
<b>Dense studded tubes</b>	3	3	3	NN


\*1970

0 = No protection, 1 = 0-1 years, 2 = 1-3 years, 3 = 3-6 years, 4 = over 6 years



# Foundation of FRBC

- The role of Cr was established in sulfidation reactions
  - Cr content > 13%
- Development and launch of composite tubing in Sweden,
- First tested in Finland



Platan, M. And Virtanen, P., Industrial Cooperation on Recovery Boiler Plant Problems in Finland, Paperi ja Puu, No 9 (1972).




# Contents

- Introduction
- Early development (bc FRBC)
- Foundation of FRBC (1964)
- **Recent development (ad FRBC)**
- FRBC highlights
- Summary





# Recent Development (ad FRBC)





# Recent Development (ad FRBC)







# Contents

- Introduction
- Early development (bc FRBC)
- Foundation of FRBC (1964)
- Recent development (ad FRBC)
- **FRBC highlights**
- Summary

# FRBC highlights I

- First RB with 304L composite furnace started up in 1972 in Sweden





# FRBC highlights II

- SOMA, New Materials in Recovery Boilers  
*1998-2001*
- SOTU II, Future Recovery Boiler -  
Constraints to Increase Power-to-Steam  
Ratio *2003-2006*
- SKYREC, Increasing Recovery Boiler  
Steam Generation to a New Level  
*2008-2011*



# FRBC highlights III

- Composite tubes
- RB materials, material issues
- BL spraying and firing
- NO<sub>x</sub> emissions, formation and reduction
- Dust formation
- Utilization of precipitator ash
- Low-temperature corrosion






# FRBC highlights IV

- Over 20 recommendations and guidelines published
- More than 60 projects completed
- Co-operation with:
  - AFRY, Åbo Akademi University, Aalto University, LUT, TAU, VTT, JYU, University of Oulu
- Best MSc Thesis award since 2009 (2000 €)



# FRBC Highlights V





# Contents

- Introduction
- Early development (bc FRBC)
- Foundation of FRBC (1964)
- Recent development (ad FRBC)
- FRBC highlights
- **Summary**



# Summary

- Introduction of composite tubing
- Utilization of CFD (Computational Fluid Dynamics) simulations in RB design
- High dry solids firing
- 2-wall secondary and tertiary air system
- Understanding BL chemistry in combustion
- Pushing the steaming ratio of RBs